

# ATTESTATION OF CONFORMITY

Issued to: CEEG (Jiangsu) Tech Co.,Ltd  
No. 69, Feitian Avenue, Jiangning Airport Economic Development Zone,  
Nanjing, Jiangsu Province, P. R. China

For the product: Energy storage systems

Trade name: CEEG

Type/Model: CHIEF-5.0K-7.68kWh, CHIEF-5.0K-11.52kWh  
CHIEF-5.0K-15.36kWh, CHIEF-8.0K-7.68kWh  
CHIEF-8.0K-11.52kWh, CHIEF-8.0K-15.36kWh  
CHIEF-10.0K-7.68kWh, CHIEF-10.0K-11.52kWh  
CHIEF-10.0K-15.36kWh, CHIEF-12.0K-7.68kWh  
CHIEF-12.0K-11.52kWh, CHIEF-12.0K-15.36kWh

Ratings: See Annex

Manufactured by: CEEG (Jiangsu) Tech Co.,Ltd  
No. 69, Feitian Avenue, Jiangning Airport Economic Development Zone,  
Nanjing, Jiangsu Province, P. R. China

Requirements: EN IEC 61000-6-1:2019  
EN IEC 61000-6-3:2021

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6149541.50

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic compatibility directive 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 19 July 2023

Number: 6149541.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.



Kreny Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2



# Annex

Document no. : 6149541.01AOC

---

## **Specification of the certified product**

CHIEF-5.0K-7.68kWh, CHIEF-5.0K-11.52kWh, CHIEF-5.0K-15.36kWh

PV Input: MPPT voltage range: 200-750 Vdc, Max. 15 A

AC grid: 380 / 400 Vac, 50 / 60 Hz, Rated AC Current to Grid: 7.2 A, Rated AC Current from Grid: 14.4 A

Battery: 254.4~345.6 Vdc, Max. charge/discharge current: 25 / 25A

CHIEF-8.0K-7.68kWh, CHIEF-8.0K-11.52kWh, CHIEF-8.0K-15.36kWh

PV Input: MPPT voltage range: 200-750 Vdc, Max. 15 A

AC grid: 380 / 400 Vac, 50 / 60 Hz, Rated AC Current to Grid: 11.6 A, Rated AC Current from Grid: 23.2 A

Battery: 381.6~518.4 Vdc, Max. charge/discharge current: 25 / 25 A

CHIEF-10.0K-7.68kWh, CHIEF-10.0K-11.52kWh, CHIEF-10.0K-15.36kWh

PV Input: MPPT voltage range: 200-750 Vdc, Max. 15 A

AC grid: 380 / 400 Vac, 50 / 60 Hz, Rated AC Current to Grid: 14.4 A, Rated AC Current from Grid: 24.1 A

Battery: 381.6~518.4 Vdc, Max. charge/discharge current: 25 / 25 A

CHIEF-12.0K-7.68kWh, CHIEF-12.0K-11.52kWh, CHIEF-12.0K-15.36kWh

PV Input: MPPT voltage range: 200-750 Vdc, Max. 15 A

AC grid: 380 / 400 Vac, 50 / 60 Hz, Rated AC Current to Grid: 17.4 A, Rated AC Current from Grid: 29 A

Battery: 508.8~691.2 Vdc, Max. charge/discharge current: 25 / 25 A

---

End